



210-1811 Victoria St.  
Prince George, BC V2L2L6  
(250)301-7898  
[www.wellnesswaterlab.com](http://www.wellnesswaterlab.com)  
[contact@wellnesswaterlab.com](mailto:contact@wellnesswaterlab.com)

**Report Status:**

- Final
- Pending
- None-Conformance

**General Information**

**Laboratory Report**

Client Name:  
First Nations Health Authority

Address:  
177 Victoria St. Suite 220 Prince George, BC V2L5R8

Report ID: **WILLIAM20200715**  
Water Sampler: DUSTIN DUNCAN  
Collection Date: 2020-07-15  
Receiving Date/Time: 2020-07-16 10:43  
Analysis Start Date/Time: 2020-07-16 14:00  
Analysis End Date/Time: 2020-07-17 14:00  
Reported Date/Time: 2020-07-18 12:00

**Bacteriology Results:**

| Project Name, Address and Source | SPL   | Lab Ref. Number | Microorganisms (MPN/100 ML) |        | Comment |
|----------------------------------|-------|-----------------|-----------------------------|--------|---------|
|                                  |       |                 | Total Coliform              | E.Coli |         |
| .15 O and M Shop                 | 3B710 | 4531            | 0.0                         | 0.0    |         |
| .02 Band Office                  | 1532  | 4532            | 0.0                         | 0.0    |         |
| Peters Dr. - 2557 Ernie Archie   | 4832  | 4533            | 0.0                         | 0.0    |         |

**Analytical Comments:**

Sample/s temperature was outside 2 to 10 °C standard range. Results should be interpreted with caution.

The information contained in this report is considered confidential and is intended for the addressee whose name is specified above. Should you receive this report by error, please notify us by phone and delete this message from your mailbox.



210-1811 Victoria St.  
 Prince George, BC V2L2L6  
 (250)301-7898  
[www.wellnesswaterlab.com](http://www.wellnesswaterlab.com)  
[contact@wellnesswaterlab.com](mailto:contact@wellnesswaterlab.com)

**Report Status:**

- Final
- Pending
- None-Conformance

**General Information**

**Laboratory Report**

Client Name:  
 First Nations Health Authority

Address:  
 177 Victoria St. Suite 220 Prince George, BC V2L5R8

Report ID: **WILLIAM20200715**  
 Water Sampler: DUSTIN DUNCAN  
 Collection Date: 2020-07-15  
 Receiving Date/Time: 2020-07-16 10:43  
 Analysis Start Date/Time: 2020-07-16 14:00  
 Analysis End Date/Time: 2020-07-17 14:00  
 Reported Date/Time: 2020-07-18 12:00

**Sample Details:**

| Project Name & Address Provided on Chain of Custody Form and/or Sample Label | SPL   | Collection Date/Time | Hold Time (hh:mm) | Field Results                     | Note |
|--|-------|----------------------|-------------------|-----------------------------------|------|
| O&M 186 GROUND HOG RD. CWS KT  | 38710 | 2020-07-15 9:35      | 28:25             | Chlorination(mg/L):YES Free: 1.63 | A    |
| BAND OFFICE 2672 INDIAN DR.CWS KT  | 1532  | 2020-07-15 10:00     | 28:00             | Chlorination(mg/L):YES Free: 1.90 | A    |
| 2557 PETERS DR. CWS KT   | 4832  | 2020-07-15 10:15     | 27:45             | Chlorination(mg/L):YES Free: 1.50 | A    |

**Notes To Clients:**

|                                |      |  |
|--------------------------------|------|--|
| A) Sample/s Temperature (°C) : | 15.0 | <i>Sample/s temperature was outside 2 to 10 °C standard range. Results should be interpreted with caution.</i> |
|--------------------------------|------|--|

a)Temperature shown in the above is the average of up to three sample temperatures in the same cooler taken at receipt  
 b)Sample Holding Time is the elapsed time between collection date/time and analysis start date/time



210-1811 Victoria St.  
 Prince George, BC V2L2L6  
 (250)301-7898  
[www.wellnesswaterlab.com](http://www.wellnesswaterlab.com)  
[contact@wellnesswaterlab.com](mailto:contact@wellnesswaterlab.com)

**Report Status:**  
 Final  
 Pending  
 None-Conformance

**General Information**

**Laboratory Report**

Client Name:  
 First Nations Health Authority

Address:  
 177 Victoria St. Suite 220 Prince George, BC V2L5R8

|                           |                        |
|---------------------------|------------------------|
| Report ID:                | <b>WILLIAM20200715</b> |
| Water Sampler:            | DUSTIN DUNCAN          |
| Collection Date:          | 2020-07-15             |
| Receiving Date/Time:      | 2020-07-16 10:43       |
| Analysis Start Date/Time: | 2020-07-16 14:00       |
| Analysis End Date/Time:   | 2020-07-17 14:00       |
| Reported Date/Time:       | 2020-07-18 12:00       |

**Quality Assurance:**

- #1 Positive Control, Klebsiella pneumoniae
- #2 Positive Control, Escherichia coli
- #3 Negative Control, Pseudomonas aeruginosa

**Methodology:**

Analyte: Total coliform & Escherichia coli  
 Method: Enzyme Substrate Colilert 24  
 Unit: MPN/100ml  
 Detection Limit: 1.0 MPN/100ml

**Guideline:**

Bacteria Growth Limit: None Detected = 0.0 = <1.0 MPN/100ml  
 Sample Temperature: 2 to 10 °C  
 Maximum Sample Holding Time: 30 hours

**References:**

British Columbia Drinking Water Protection Act  
 Guideline for Canadian Drinking Water Quality  
 Standard Methods for the Examination of Water and Wastewater, 23rd Edition  
 Enhanced Water Quality Assurance Program (EWQA)

**PHO Approval:**

[Provincial Health Officer Approved Laboratory List](#)

**Acronyms:**

|  |   |                                    |
|--|---|------------------------------------|
| <b>BML:</b> Below Minimum Limit                | <b>MPN:</b> Most Probable Number (per 100 ml) | <b>PW:</b> Private Well            |
| <b>BT:</b> Bathroom Tap                        | <b>NA:</b> Not Applicable                     | <b>SC:</b> See Comment             |
| <b>BW:</b> Bottled Water                       | <b>NC:</b> Non-Conformance                    | <b>SPL:</b> Sampling Point Locator |
| <b>CWS:</b> Community Water System             | <b>NCD:</b> No Collection Date                | <b>t:</b> Total Chlorine           |
| <b>EC:</b> E. coli ( <i>Escherichia coli</i> ) | <b>NCT:</b> No Collection Time                | <b>TC:</b> Total Coliform          |
| <b>EML:</b> Exceeded Maximum Limit             | <b>NI:</b> Not Indicated                      | <: Below                           |
| <b>f:</b> Free Chlorine                        | <b>NR:</b> No Result                          | >: Above                           |
| <b>IL:</b> Illegible                           | <b>NSQ:</b> Not Sufficient Quantity           | °C: Degree Celsius                 |
| <b>KT:</b> Kitchen Tap                         | <b>NT:</b> Not Tested                         | *: Indicates Criteria Not Met      |
| <b>MAC:</b> Maximum Acceptable Concentration   | <b>OT:</b> Outside Tap                        |                                    |



210-1811 Victoria St.  
Prince George, BC V2L2L6  
(250)301-7898  
[www.wellnesswaterlab.com](http://www.wellnesswaterlab.com)  
[contact@wellnesswaterlab.com](mailto:contact@wellnesswaterlab.com)

**Report Status:**

- Final
- Pending
- None-Conformance

**General Information**

**Laboratory Report**

Client Name:  
First Nations Health Authority

Address:  
177 Victoria St. Suite 220 Prince George, BC V2L5R8

|                           |                        |
|---------------------------|------------------------|
| Report ID:                | <b>WILLIAM20200715</b> |
| Water Sampler:            | DUSTIN DUNCAN          |
| Collection Date:          | 2020-07-15             |
| Receiving Date/Time:      | 2020-07-16 10:43       |
| Analysis Start Date/Time: | 2020-07-16 14:00       |
| Analysis End Date/Time:   | 2020-07-17 14:00       |
| Reported Date/Time:       | 2020-07-18 12:00       |

**Signature Page:**

The results and Quality Control validations in this report were reviewed and approved by:

Arian Javaherdashti, MLT, CSMLS, Senior Analyst

The test results and additional information provided in this report applies only to the listed samples and is relevant only for the date, time and exact location of collections. Samples are tested as received and Wellness Water Testing Laboratory Inc. assumes no responsibility for the method of collection or samples shipment condition and disclaims any liability for damages arising from interpretation of results. The person and/or company performing the field work is advised to consult British Columbia Drinking Water official regulatory references when evaluating compliance. Please direct your inquiries about this report to us by phone at 250-301-7898.