



210-1811 Victoria St.
Prince George, BC V2L2L6
(250)301-7898

www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
Final

General Information

Laboratory Report

Client Name:

JOYCE, PATTI
WILLIAMS LAKE
First Nations Health Authority

Bill To:

First Nations Health Authority

Address:

177 Victoria St. Suite 220, Prince George, BC V2L5R8

Report ID: **WILLIAMS20220622**
Sampler: WYCOTTE, TOMMY
Collection Date: 2022-06-22
Receiving Date/Time: 2022-06-23 11:40
Analysis Start Date/Time: 2022-06-23 12:50
Analysis End Date/Time: 2022-06-24 12:50
Reported Date/Time: 2022-06-24 16:00

The information contained in this report is considered confidential and is intended for the addressee whose name is specified above. Should you receive this report by error, please notify us by phone and delete this message from your mailbox.

Contents	Section #
Bacteriology Results	1
Analytical Comments	2
Sample Details	3
Note To Clients	4
Quality Assurance	5
Methodology	6
Guideline	7
References	8
PHO Approval	9
Acronyms	10
Signature Page	11
Additional Documents	12



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898

www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
Final

General Information

Laboratory Report

Client Name:
 JOYCE, PATTI
 WILLIAMS LAKE
 First Nations Health Authority

Bill To:
 First Nations Health Authority

Address:
 177 Victoria St. Suite 220, Prince George, BC V2L5R8

Report ID: **WILLIAMS20220622**
 Sampler: WYCOTTE, TOMMY
 Collection Date: 2022-06-22
 Receiving Date/Time: 2022-06-23 11:40
 Analysis Start Date/Time: 2022-06-23 12:50
 Analysis End Date/Time: 2022-06-24 12:50
 Reported Date/Time: 2022-06-24 16:00

1. Bacteriology Results:

#	Project Name, Address and Source	Site Code	Lab Reference Number	Microorganisms (MPN/100 ML)		Comment
				Total Coliform	E.Coli	
1	.15 O and M Shop	15463	15143	<1	<1	
2	.01 Sugar Cane Health Centre	15976	15144	<1	<1	
3	ROSEANNE MCGEORGE,CWS.K.T	15570	15145	<1	<1	
4	.04 Chief Will-Yum Store	15465	15146	<1	<1	
5	NEW ADMIN BUILDING CWS KT	21163	15147	<1	<1	

2. Analytical Comments:

●See section #12 for additional documents



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898

www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
Final

General Information

Laboratory Report

Client Name:

JOYCE, PATTI
 WILLIAMS LAKE
 First Nations Health Authority

Bill To:

First Nations Health Authority

Address:

177 Victoria St. Suite 220, Prince George, BC V2L5R8

Report ID: **WILLIAMS20220622**
 Sampler: WYCOTTE, TOMMY
 Collection Date: 2022-06-22
 Receiving Date/Time: 2022-06-23 11:40
 Analysis Start Date/Time: 2022-06-23 12:50
 Analysis End Date/Time: 2022-06-24 12:50
 Reported Date/Time: 2022-06-24 16:00

3. Sample Details:

#	Project Name & Address Provided on Chain of Custody Form and/or Sample Label	Source	Collection Date/Time	Hold Time (hh:mm)	Chlorination (mg/L)		Note
					Free	Total	
1	.15 O and M Shop	Sugar Cane Williams Lake CWS	2022-06-22 8:57	27:53	0.41	0.53	
2	.01 Sugar Cane Health Centre	Sugar Cane Williams Lake CWS	2022-06-22 9:25	27:25	0.34	0.41	
3	ROSEANNE MCGEORGE,CWS.K.T	Sugar Cane Williams Lake CWS	2022-06-22 9:55	26:55	0.42	0.53	
4	.04 Chief Will-Yum Store	Sugar Cane Williams Lake CWS	2022-06-22 12:43	24:07	0.44	0.46	
5	NEW ADMIN BUILDING CWS KT	Sugar Cane Williams Lake CWS	2022-06-22 13:20	23:30	0.44	0.50	

4. Note To Clients:

A	Sample/s Temperature (°C) :	7.0	
B	Sample/s Holding Time (hh):	<30	
C	Verbal Notification:	NO	
D	Additional Documents:	YES	●See section #12 for additional documents

a)Temperature shown in the above is the average of up to three sample temperatures in the same cooler taken at receipt

b)Sample Holding Time is the elapsed time between collection date/time and analysis start date/time



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898

www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
Final

General Information

Laboratory Report

Client Name:

JOYCE, PATTI
 WILLIAMS LAKE
 First Nations Health Authority

Report ID: **WILLIAMS20220622**

Sampler: WYCOTTE, TOMMY

Collection Date: 2022-06-22

Receiving Date/Time: 2022-06-23 11:40

Analysis Start Date/Time: 2022-06-23 12:50

Analysis End Date/Time: 2022-06-24 12:50

Reported Date/Time: 2022-06-24 16:00

Bill To:

First Nations Health Authority

Address:

177 Victoria St. Suite 220, Prince George, BC V2L5R8

5. Quality Assurance:

- #1 Positive Control, Klebsiella pneumoniae
- #2 Positive Control, Escherichia coli
- #3 Negative Control, Pseudomonas aeruginosa

6. Methodology:

Analyte: Total coliform & Escherichia coli
 Method: Enzyme Substrate Colilert 24
 Unit: MPN/100ml
 Detection Limit: 1.0 MPN/100ml

7. Guideline:

Bacteria Growth Limit: None Detected = 0.0 = <1.0 MPN/100ml
 Sample Temperature: 2 to 10 °C
 Maximum Sample Holding Time: 30 hours

8. References:

British Columbia Drinking Water Protection Act
 Guideline for Canadian Drinking Water Quality
 Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 Enhanced Water Quality Assurance Program (EWQA)

9. PHO Approval:

[Provincial Health Officer Approved Laboratory List](#)

10. Acronyms:

BML: Below Minimum Limit	MPN: Most Probable Number (per 100 ml)	PW: Private Well
BT: Bathroom Tap	NA: Not Applicable	SC: See Comment
BW: Bottled Water	NC: Non-Conforming	SPL: Sampling Point Locator
CWS: Community Water System	NCD: No Collection Date	t: Total Chlorine
EC: E. coli (<i>Escherichia coli</i>)	NCT: No Collection Time	TC: Total Coliform
EML: Exceeded Maximum Limit	NI: Not Indicated	<: Below
f: Free Chlorine	NR: No Result	>: Above
IL: Illegible	NSQ: Not Sufficient Quantity	°C: Degree Celsius
KT: Kitchen Tap	NT: Not Tested	*: Indicates Criteria Not Met
MAC: Maximum Acceptable Concentration	OT: Outside Tap	
mg/L: Milligram per litre	ppm: Part per million	



210-1811 Victoria St.
Prince George, BC V2L2L6
(250)301-7898

www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
Final

General Information

Laboratory Report

Client Name:

JOYCE, PATTI
WILLIAMS LAKE
First Nations Health Authority

Bill To:

First Nations Health Authority

Address:

177 Victoria St. Suite 220, Prince George, BC V2L5R8

Report ID:	WILLIAMS20220622
Sampler:	WYCOTTE, TOMMY
Collection Date:	2022-06-22
Receiving Date/Time:	2022-06-23 11:40
Analysis Start Date/Time:	2022-06-23 12:50
Analysis End Date/Time:	2022-06-24 12:50
Reported Date/Time:	2022-06-24 16:00

11. Signature Page:

The results and Quality Control validations in this report were reviewed and approved by:

Arian Javaherdashti, MLT, CSMLS, Senior Analyst

The test results and additional information provided in this report applies only to the listed samples and is relevant only for the date, time and exact location of collections. Samples are tested as received and Wellness Water Testing Laboratory Inc. assumes no responsibility for the method of collection or samples shipment condition and disclaims any liability for damages arising from interpretation of results. The person and/or company performing the field work is advised to consult British Columbia Drinking Water official regulatory references when evaluating compliance. Please direct your inquiries about this report to us by phone at 250-301-7898.

12. Additional Documents:

- Please see attached copy of Chain of Custody form

CHAIN OF CUSTODY FORM

Nation/Community Name:
Environmental Public Health Services
First Nations Health Authority

PRINT FULL NAME

Williams Lake First Nation

Sampler:

Tommy Wycotte
22 06, 2022

Date of Collection:

LID/WSI Location ID Number/ Water System ID	Time of Collection 00:00 AM/PM	Site Name/Address Project Type: CWS: Community Water System, PW: Private Well Location: KT: Kitchen Tap, BT: Bathroom Tap, OT: Outside Tap, BW: Bottled Water	Chlorinated (mg/L)	FOR LAB USE ONLY (DO NOT WRITE IN THIS SECTION)
1. 477-15463	8:57 am	Otm office, CWS, .K.T.	Yes <input checked="" type="radio"/> No <input type="radio"/> free: 0.41 total: 0.53	WWTL 15143
2. 477-15976	9:25 am	Health Centre, CWS, .K.T.	Yes <input checked="" type="radio"/> No <input type="radio"/> free: 0.34 total: 0.41	WWTL 15144
3. 477-15570	9:55 am	Roseanne McGregor, CWS, .K.T.	Yes <input checked="" type="radio"/> No <input type="radio"/> free: 0.42 total: 0.53	WWTL 15145
4. 477-15465	12:43 pm	Chief Will Yum Store, CWS, .B.T.	Yes <input checked="" type="radio"/> No <input type="radio"/> free: 0.44 total: 0.46	WWTL 15146
5. 477-21163	1:20 pm	New Admin. Building, CWS, .K.T.	Yes <input checked="" type="radio"/> No <input type="radio"/> free: 0.44 total: 0.50	WWTL 15147
6.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
7.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
8.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
9.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
10.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
11.			Yes <input type="radio"/> No <input type="radio"/> free: total:	
12.			Yes <input type="radio"/> No <input type="radio"/> free: total:	

FOR LAB USE ONLY (DO NOT WRITE IN THIS SECTION)

Received By: AS

Date: 23 June 22

Time: 11:40

Temperature: 7.0 °C

Note: